



Mojave Desert Air Quality Management District
14306 Park Avenue, Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

NTC - Notice to Comply
MD00003020

Issue Date: 11/15/2024	Close Date:	Status: Open
Field-Issued NTC No:	Permit Number: E014722	Inspector: Matthew Lipke
Contact: Daniel B. Smith	Phone: 760-247-1101	Email: avfwd@gmail.com
Company: Apple Valley Foothill County Water District		Company Nbr: 2896
Address: 22545 Del Oro Road, Apple Valley, CA 92308		
Facility: Apple Valley Foothill County Water District		Facility Nbr: 4311
Address: District Wide, MDAQMD, CA 92392		

VIOLATIONS

Permitted generator(portable) being used in stationary capacity
Violated Rules, Regulations and/or Standards: District Rule 1302

RECOMMENDATION

1. Make the generator a portable source again(aka put on a trailer) to be in compliance with current permit conditions/ or 2. Submit Permit Modification to be in compliance, so generator can be in a stationary capacity (pending approval) / Or 3. Stop operation of generator completely within Mojave Desert District boundaries
Correction Due Date: 12/06/2024
Extended Due Date:

CORRECTION

Corrected By: _____
Title: _____
Correction Date: _____

Signature: _____

Matthew Lipke
Air Quality Specialist I